

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 135 Hook Road
Lab Code: R2401068-001

Service Request: R2401068
Date Collected: 02/08/24 11:15
Date Received: 02/08/24 13:35

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	11	0.50	1	02/15/24 17:57	
Bromoform	ND U	0.50	1	02/15/24 17:57	
Chloroform	22	0.50	1	02/15/24 17:57	
Dibromochloromethane	2.4	0.50	1	02/15/24 17:57	
Trihalomethanes, Total	35	2.0	1	02/15/24 17:57	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	78	70 - 130	02/15/24 17:57	
Bromofluorobenzene	76	70 - 130	02/15/24 17:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 375 County Rd 28
Lab Code: R2401068-002

Service Request: R2401068
Date Collected: 02/08/24 11:00
Date Received: 02/08/24 13:35

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	11	0.50	1	02/15/24 18:22	
Bromoform	ND U	0.50	1	02/15/24 18:22	
Chloroform	23	0.50	1	02/15/24 18:22	
Dibromochloromethane	2.4	0.50	1	02/15/24 18:22	
Trihalomethanes, Total	36	2.0	1	02/15/24 18:22	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	75	70 - 130	02/15/24 18:22	
Bromofluorobenzene	77	70 - 130	02/15/24 18:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 448 Sheldon Rd
Lab Code: R2401068-003

Service Request: R2401068
Date Collected: 02/08/24 10:39
Date Received: 02/08/24 13:35

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	9.5	0.50	1	02/16/24 17:22	
Bromoform	ND U	0.50	1	02/16/24 17:22	
Chloroform	19	0.50	1	02/16/24 17:22	
Dibromochloromethane	2.3	0.50	1	02/16/24 17:22	
Trihalomethanes, Total	31	2.0	1	02/16/24 17:22	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	74	70 - 130	02/16/24 17:22	
Bromofluorobenzene	75	70 - 130	02/16/24 17:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 5923 Loomis Rd
Lab Code: R2401068-004

Service Request: R2401068
Date Collected: 02/08/24 11:45
Date Received: 02/08/24 13:35

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	12	0.50	1	02/16/24 16:32	
Bromoform	ND U	0.50	1	02/16/24 16:32	
Chloroform	24	0.50	1	02/16/24 16:32	
Dibromochloromethane	2.7	0.50	1	02/16/24 16:32	
Trihalomethanes, Total	38	2.0	1	02/16/24 16:32	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	75	70 - 130	02/16/24 16:32	
Bromofluorobenzene	74	70 - 130	02/16/24 16:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 5150 North St
Lab Code: R2401068-005

Service Request: R2401068
Date Collected: 02/08/24 10:11
Date Received: 02/08/24 13:35

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	9.5	0.50	1	02/16/24 16:57	
Bromoform	ND U	0.50	1	02/16/24 16:57	
Chloroform	16	0.50	1	02/16/24 16:57	
Dibromochloromethane	2.2	0.50	1	02/16/24 16:57	
Trihalomethanes, Total	28	2.0	1	02/16/24 16:57	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	77	70 - 130	02/16/24 16:57	
Bromofluorobenzene	75	70 - 130	02/16/24 16:57	