

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 5290 North Street  
**Lab Code:** R2503363-001

**Service Request:** R2503363  
**Date Collected:** 04/01/25 08:18  
**Date Received:** 04/01/25 14:15  
**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/01/25 19:35 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/01/25 19:35 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 6026 State Route 96  
**Lab Code:** R2503363-002

**Service Request:** R2503363  
**Date Collected:** 04/01/25 07:58  
**Date Received:** 04/01/25 14:15  
**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/01/25 19:35 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/01/25 19:35 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 187 County Road 8  
**Lab Code:** R2503363-003

**Service Request:** R2503363  
**Date Collected:** 04/01/25 07:43  
**Date Received:** 04/01/25 14:15

**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/01/25 19:35 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/01/25 19:35 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 2440 Andrews Road  
**Lab Code:** R2503692-001

**Service Request:** R2503692  
**Date Collected:** 04/08/25 09:11  
**Date Received:** 04/08/25 14:30

**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/08/25 18:39 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/08/25 18:39 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 1802 State Route 332  
**Lab Code:** R2503692-002

**Service Request:** R2503692  
**Date Collected:** 04/08/25 08:52  
**Date Received:** 04/08/25 14:30  
**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/08/25 18:39 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/08/25 18:39 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 1500 Fox Road  
**Lab Code:** R2503692-003

**Service Request:** R2503692  
**Date Collected:** 04/08/25 08:27  
**Date Received:** 04/08/25 14:30

**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/08/25 18:39 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/08/25 18:39 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 5102 North Road  
**Lab Code:** R2504310-001

**Service Request:** R2504310  
**Date Collected:** 04/22/25 08:02  
**Date Received:** 04/22/25 14:06

**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/22/25 18:57 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/22/25 18:57 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** County Road 28 & County Road 41  
**Lab Code:** R2504310-002

**Service Request:** R2504310  
**Date Collected:** 04/22/25 07:52  
**Date Received:** 04/22/25 14:06

**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/22/25 18:57 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/22/25 18:57 |   |



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 335 Hook Road  
**Lab Code:** R2504310-003

**Service Request:** R2504310  
**Date Collected:** 04/22/25 07:31  
**Date Received:** 04/22/25 14:06

**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/22/25 18:57 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/22/25 18:57 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 5150 North Street  
**Lab Code:** R2504556-001

**Service Request:** R2504556  
**Date Collected:** 04/29/25 08:30  
**Date Received:** 04/29/25 13:33  
**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/29/25 18:59 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/29/25 18:59 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** County Road 8 & Townline Road  
**Lab Code:** R2504556-002

**Service Request:** R2504556  
**Date Collected:** 04/29/25 08:50  
**Date Received:** 04/29/25 13:33

**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/29/25 18:59 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/29/25 18:59 |   |

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 1000 County Road 8  
**Lab Code:** R2504556-003

**Service Request:** R2504556  
**Date Collected:** 04/29/25 09:05  
**Date Received:** 04/29/25 13:33

**Basis:** NA

Inorganic Parameters

| Analyte Name     | Analysis Method | Result | Units     | MRL | Dil. | Date Analyzed  | Q |
|------------------|-----------------|--------|-----------|-----|------|----------------|---|
| Coliform, Total  | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/29/25 18:59 |   |
| Escherichia coli | SM 9223 B       | Absent | CFU/100mL | -   | 1    | 04/29/25 18:59 |   |